

CERTIFICATE of Conformity



Certificate No.: MK 69240822 0001
Test Report No.: 28211358 001
Certificate Holder: Fronius International GmbH
Günter Fronius strasse 1.
A-4600 Wels-Thalheim,
Austria
Manufacturer: Fronius International GmbH
Fronius Strasse 5.
A-4642 Sattledt,
Austria
Product: Photovoltaic (PV) grid-tie inverter
Fronius CL inverter family
Identification: Type designation: a) Fronius CL 36.0
b) Fronius CL 48.0
c) Fronius CL 60.0
Max. DC input voltage: 600V
Operating DC input voltage: 230-500V
Max. DC input current (A): a) 167,8
b) 223,4
c) 280,2
Nominal AC output power (kW): a) 36 b) 48 c) 60
Max AC output current (A): a) 52,2
b) 69,6
c) 87,0
Nominal voltage: 400/230V, 50Hz, 3 phase
Trademark: Fronius
Tested according to: EN 61000-3-2:2006+A1+A2
EN 61000-3-3:2008
EN 61000-6-2:2005
EN 61000-6-4:2007

This certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the requirements stated above. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date of Issue:
Budapest, 2011-05-13



Certification Body

Gabor Kassai
Gabor Kassai

TÜV Rheinland InterCert Kft. – Product Certification Body — H-1132 Budapest, Váci út 48/A-B — www.tuv.hu